



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6102CS0529

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of water supply
Produkte der Wasserversorgung

Distributor
Vertreiber

VSH Fittings BV
Oude Amersfoortseweg 99, NL-1212 AA Hilversum

Product Category
Produktart

stop valves for drinking water: ball valve (6102)

Product Description
Produktbezeichnung

ball valve for the drinking water installation

Model
Modell

VSH XPress

Test Reports
Prüfberichte

type testing: 160602254/001a from 10.03.2017 (KIW)
type testing: 160602254/001b from 10.03.2017 (KIW)
KTW testing: K-274423-16-Ko/st from 19.08.2016 (WHY)
hygienic testing: W-274382e-16-SI/Krü from 18.08.2016 (WHY)
KTW testing: K-274424-16-Ko/st from 19.08.2016 (WHY)

Test Basis
Prüfgrundlagen

DVGW W 570-1 (01.03.2013)
DIN EN 13828 (01.12.2003)
UBA METALLE (26.03.2018)
UBA ELASTOM (16.03.2016)
UBA KTW (07.03.2016)
DVGW W 270 (01.11.2007)

Date of Expiry / File No.
Ablaufdatum / Aktenzeichen

10.03.2022 / 17-0506-WNE

730208-01-A-DE

04.10.2018 GI B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 10 mm	connections: male thread G3/8"; female thread G3/8"; press connection: 15 mm
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 15 mm	connections: female thread G1/2"; press connection: 18 mm; swivel nut: G3/4"
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 20 mm	connections: male thread G3/4"; female thread G3/4"; press connection: 22 mm
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 25 mm	connections: male thread G1"; female thread G1"; press connection: 28 mm
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 32 mm	connections: female thread G1 1/4"; press connection: 35 mm; swivel nut: G1 1/2"
VSH XPress	type of construction: reduced bore pressure rating: PN 10 nominal diameter: DN 40 mm	connections: female thread G1 1/2"; press connection: 42 mm
VSH XPress	type of construction: full bore pressure rating: PN 10 nominal diameter: DN 50 mm	connections: male thread G2"; female thread: G2"; press connection: 54 mm

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
DW-8511BR0536	pipe joint for pipes in drinking water installation systems	XPress Stainless/XPress Stainless	VSH Fittings BV

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

The tested connections can get combined within one nominal size.

Stem height: high and low