



SWEDISH TYPE APPROVAL 1379

WITH DECISION ON PRODUCTION CONTROL

KEYWORD: Tap water

Holder: BROEN A/S

Skovvej 30, 5610 Assens, Denmark

Tel: + 45 6471 20 95

E-mail: broen@broen.com

Webb: www.broen.com

Product name: BROEN Full Flow

Ball valves full flow are made of 100 % stainless steel with no brass included. The valves are connected with varying connections such as flanged, threaded and weld end. Approved for dimensions: DN10, 15, 20, 25, 32, 40 and 50

Intended use

Shut-off valve for domestic hot and cold water or heating in the property where the highest occurring operating pressure does not exceed 1.0 MPa and where the water momentarily does not exceed 95 °C or continuously does not exceed 70 °C.

Approval

Products made and installed according to related documents are approved with respect to the following sections of the Swedish Building Regulations (BBR):

Installations for tap water – paragraph 2	6:62*
Design – paragraph 1 and 4	6:625

* The products meet the requirements of the BFS 2014: 3

For the intended use the products meets the following requirements of PBL, regulations governing the technical properties of materials, products etc. used in construction works Chapter 8 Section 4 about the technical characteristics of buildings and constructions.

3. Protection with regard to hygiene, health and environment
4. Safety in use

Appendix 1: Associated documents	21/03/2017
Appendix 2: Product marking	21/03/2017
Appendix 3: Control	21/03/2017
Appendix 4: Basis for approval	21/03/2017

Kiwa Sverige AB
Campus Gräsvik 1
SE-371 75 Karlskrona

Tel +46 (0)455-30 56 00
Fax +46 (0)455-104 36
bygg@kiwa.se
www.kiwa.se




Date of decision: 21/03/2017

Ref. no: 364/16

Valid until: 20/03/2022

Kiwa Sverige AB


Magnus Jerlmark
Technical manager


Deo Yamabo
Project manager